

Drinking Water Quality and Compliance Annual Notice to Consumers

Introduction

Saskatchewan Environment (SE) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Town of Rosthern** water quality and sample submission compliance record for the **Jan 1 - Dec 31, 2007** time period. This report was completed on **Jan 10, 2008**. Readers should refer to SE's "Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: <http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm>.

Water Quality Standards Bacteriological Quality

Parameter/Location Limit	Required	# of Positive Regular Submitted	Regular samples submitted %
Total Coli form and Organisms/100ml Background Bacteria Less than 200/100 mL	52	54	0

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Sub % OK
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.59 – 2.19	.42 – 2.02	52	100

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter Limit (mg/L)	Range	# Test Performed	# Tests Requirements	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	373	365	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required
1.0	.05 - .28	0	.28	

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on **May 22, 2007**. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC(mg/L)	Sample Result(s)	# Samples Exceeding Limit
Arsenic	25	2.1	none
Barium	1	.23	"
Boron	5	.04	"
Cadmium	.005	<0.0001	"
Chromium	.05	<0.0005	"
Fluoride	na	.15	"
Lead	.01	.0001	"
Nitrate (avg.*)	45	4.9	"
Selenium	.01	.0003	"
Uranium	20	1.8	"

Chemical – Trihalomethanes (THMs)

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	not required as per permit		

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed.

General Chemical

Parameter	Aesthetic Objectives * (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500	233	1	1
Bicarbonate	No Objective	284	1	1
Calcium	No Objective	68	1	1
Carbonate	No Objective	<1	1	1
Chloride	250	4	1	1
Conductivity	No Objective	469	1	1
Hardness	800	239	1	1
Magnesium	200	17	1	1
PH	No Objective	8.06	1	1
Sodium	300	6.2	1	1
Sulphate	500	17	1	1
Total dissolved Solids	1500	281	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in **2007** and submitted on **May 22, 2007**. Sample results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

**Town of Rosthern, Office
Box 416
SOK 3R0
306 - 232 - 4313**

